



Exergy and Energy Analysis of Low Temperature District Heating Network

Li, Hongwei; Svendsen, Svend

Publication date:
2011

Document Version
Publisher's PDF, also known as Version of record

[Link back to DTU Orbit](#)

Citation (APA):

Li, H., & Svendsen, S. (2011). Exergy and Energy Analysis of Low Temperature District Heating Network. Abstract from 24th International Conference on Efficiency, Cost, Optimization, Simulation and Environmental Impact of Energy Systems, Novi Sad, Serbia.

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

Exergy and Energy Analysis of Low Temperature District Heating Network

Hongwei Li^a, Svend Svendsen^b

*^aCivil Engineering Department,
Technical University of Denmark, Denmark
Building 118, Brovej
DK-2800 Kgs.Lyngby, Denmark
Email: hong@byg.dtu.dk*

*^bCivil Engineering Department,
Technical University of Denmark, Denmark
Building 118, Brovej
DK-2800 Kgs.Lyngby, Denmark
Email: ss@byg.dtu.dk*

Abstract

Low temperature district heating (LTDH) with reduced network supply and return temperature provides better match of the low quality building thermal demand and the low quality waste heat supply. In this paper, an exemplary LTDH network was designed for 30 low energy demand residential houses, which is in line with a pilot project that is carrying out in Denmark with network supply/return temperature at 55°C/25 °C. The consumer domestic hot water (DHW) demand is supplied with a special designed district heating (DH) storage tank. The space heating (SH) demand is supplied with a low temperature radiator. The network thermal and hydraulic conditions were simulated under steady state with an in-house district heating network design and simulation code. Through simulation, the overall system energetic and exergetic efficiencies were calculated and the exergy losses for the major district heating system components were identified.