



## New treatment technology to remove worms in biological sand filter

**Christensen, Sarah Christine Boesgaard; Larsen, Sille Lyster; Asmussen, Olaf; Boe-Hansen, Rasmus; Albrechtsen, Hans-Jørgen**

*Publication date:*  
2016

*Document Version*  
Publisher's PDF, also known as Version of record

[Link back to DTU Orbit](#)

*Citation (APA):*

Christensen, S. C. B., Larsen, S. L., Asmussen, O., Boe-Hansen, R., & Albrechtsen, H-J. (2016). *New treatment technology to remove worms in biological sand filter*. Abstract from 10th Nordic Drinking Water Conference, Reykjavik, Iceland.

---

### General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

A photograph of two workers in high-visibility safety gear. The worker on the left is wearing a yellow jacket and helmet, and is operating a high-pressure water sprayer. The worker on the right is wearing an orange and black jacket and helmet, and is holding a hose. A large spray of water is directed towards the right. The background shows a grey stone wall and green foliage.

The 10<sup>th</sup> Nordic

**DRINKING  
WATER  
CONFERENCE**

Reykjavík, September 28–30 2016

**PROGRAM**

**Abstract title:** New treatment technology to remove worms in biological sand filter

**Author(s):** Sarah C.B. Christensen; Sille L. Larsen; Olaf Asmussen; Rasmus Boe-Hansen; Hans-Jørgen Albrechtsen

**Country:** Denmark

**Organization(s):** DTU Environment, Technical University of Denmark

**Organization(s) type:** University

**Abstract text:**

Introduction

Water treatment in biological rapid sand filter is a sustainable green technology which is extremely resource and energy efficient. Since all Danish drinking water is ground water based, the simple treatment consists of aeration and filtration without use of disinfectants. Microbiological processes remove e.g. ammonia, manganese and iron in the raw water, and it is therefore a prerequisite that the proper functional bacteria are present and under the right conditions. However biological sand filters have proven also to host higher organisms such as segmented worms (Oligochaeta). The largest worms found in Danish sand filters were 10 cm long. The large segmented worms are an aesthetic challenge to the water utilities as worms in tap water have been reported by consumers.

Danish utilities have previously used high concentrations of chlorine to remove worms from full scale filters. However this treatment killed the functional bacteria, and a utility reported that sand filters treated with sodium hypochlorite did not meet the required level of ammonia removal for half a year after treatment.

Aims

The main aim of this study was to:

- develop a technology to remove worms from biological sand filters while minimising the effects on the water treating abilities of the filter

Secondary aims were to:

- gather information from Danish utilities on occurrence and removal of worms in sand filters
- develop methods to collect worms in sand filters
- identify worms from Danish water works

Methods

The study was conducted during 2014 and 2015 and included field sampling, laboratory studies and analyses as well as field studies. Furthermore the study included data of worm occurrences at Danish utilities gathered since 2007

Results

Nine methods to collect worms from sand filters were developed and applied through sampling campaigns at Danish water works.

Worms from a Danish utility were identified by DNA analysis as "Dendrodrilus rubidus". Since Dendrodrilus rubidus is a terrestrial worm, survival studies with closely related terrestrial worms were conducted in drinking water with filter sand to investigate whether terrestrial worms are able to survive in water. As of today, the investigated compost worms Eisenia fetida and Eisenia veneta have thrived

in aerated water for 14 months.

Worms were registered at water works throughout Denmark and were hence not confined to a specific area. All infested water works had relatively high concentrations of methane in the raw water, which is a source of organic compounds if it is not completely stripped off but utilized by methane-oxidizing bacteria. High levels of organic compounds in sand filters support populations of higher organisms such as worms.

Four treatment technologies were tested on *Eisenia fetida* and *Eisenia veneta* in laboratory experiments; hydrogen peroxide (H<sub>2</sub>O<sub>2</sub>), nitrogen (N<sub>2</sub>), carbon dioxide (CO<sub>2</sub>) and monochloramine (NH<sub>2</sub>Cl).

CO<sub>2</sub> treatment and chlorine treatment as reference (NaOCl) were also investigated in pilot filter columns at a water works since they were the only methods which eliminated the worms within two days.

All the worms in the filter columns were killed after six hours of NaOCl treatment, which was also the result of six hours of CO<sub>2</sub> treatment. All worms survived in the control without treatment. Treatment with NaOCl impaired the functionality of the filter and no ammonium was removed from the water after treatment. CO<sub>2</sub> treatment on the other hand did not reduce ammonium removal, and 100 % removal was measured immediately after the treatment was completed. Hence, CO<sub>2</sub> treatment of worms in biological sand filters was an efficient method, which did not impede the functionality of the filter.

#### Acknowledgements

The study was supported by the Programme for Green Technology by the Danish EPA and two Danish utilities.