



Microbial biotechnologies for potable water production

Fowler, S. Jane; Smets, Barth F.

Published in:
Microbial Biotechnology

Link to article, DOI:
[10.1111/1751-7915.12837](https://doi.org/10.1111/1751-7915.12837)

Publication date:
2017

Document Version
Publisher's PDF, also known as Version of record

[Link back to DTU Orbit](#)

Citation (APA):
Fowler, S. J., & Smets, B. F. (2017). Microbial biotechnologies for potable water production. *Microbial Biotechnology*, 10(5), 1094-1097. <https://doi.org/10.1111/1751-7915.12837>

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

Microbial biotechnologies for potable water production

S. Jane Fowler  and Barth F. Smets* 

DTU Environment, Department of Environmental Engineering, Technical University of Denmark, Byngningstorvet 115, 2800 Kgs Lyngby, Denmark.

The WHO suggests that humans require an absolute minimum of 7.5 L of water per day, while a minimum of about 20 L of water per person per day is recommended to ensure adequate hygienic standards. With a population of 7.5 billion, this works out to 150 billion litres of safe freshwater daily, globally. Much more than this is generally consumed in developed nations, while less than adequate amounts of safe water are available in some regions. Although sufficient freshwater resources exist to meet global water needs, the major limitation is the lack of infrastructure in some regions for production and distribution of safe water. The global provision of safe water is a key aim of UN Sustainable development goal (SDG) 6, but this goal also intersects closely with SDG 13, climate change, requiring energy efficiency and minimal GHG emissions, and SDG 12, requiring sustainable global water consumption and production patterns and reductions in pollution of water resources. Safe drinking water has a quality that would not present any significant risk to health over a lifetime of consumption. While physical and chemical disinfection processes may remain essential to reduce the pathogenic burden during water treatment, we believe that increased exploitation of microbiological processes for drinking water treatment is the most sustainable way forward for the global provision of safe water. Biological drinking water treatment processes are available for the removal of a wide range of chemical contaminants, are less costly and less energy intensive than advanced chemical or physical treatment methods and are robust over a wide range of operating conditions and water qualities. Furthermore, they reduce the use of potentially hazardous chemicals and typically result in complete mineralization of contaminants, rather than concentration in a waste stream,

which then necessitates specialized treatment and/or disposal. In addition, recent and ongoing research indicates that providing biologically stable water can be accomplished by fostering the presence of a natural resident, non-pathogenic drinking water microbiome that can resist pathogen invasion in water supplies, which can be achieved through the use of biological drinking water treatment processes.

The major sources of drinking water are surface water and groundwater. Both forms of water are generally not safe at the source and require some form of treatment to be considered potable. To ensure adequate water quality, regulatory guidelines exist for (i) biological contaminants (pathogenic bacteria, protozoa, viruses and helminths), (ii) inorganic chemicals (metals, oxyanions, nitrogen species and radionuclides), and (iii) organic chemicals (natural organic matter and synthetic organic chemicals from agricultural, industrial and residential use). In regions where disinfection is used in drinking water treatment, disinfectant residuals and disinfection by-products are also typically regulated due to their potential adverse health effects. In addition, physical aspects of the water including colour, odour and taste also contribute to water quality.

Historically and up to the present day, microbial processes have been used in the production of potable water. Biological drinking water treatment has been widespread since the 1800s in the form of slow sand filtration or bank filtration (Schubert, 2002; Logsdon *et al.*, 2011). While historically, biological water treatment was empirical, we now have the technology and tools to understand the structure and function of the microbial communities involved in biological water treatment, potentially enabling control and optimization, making these processes even more attractive. Unfortunately, the use of biological processes for drinking water production has been in decline in recent years due to misconceptions regarding a relationship between the presence and exploitation of microbes in drinking water treatment and the presence of pathogens. In North America (and many regions around the world), disinfection is routinely used in an effort to *sterilize* drinking water. Despite the use of disinfectants and the presence of disinfectant residuals in distribution systems, 10^3 – 10^9 bacteria per mL are still present in drinking water at the tap (Hammes *et al.*, 2008; Lautenschlager *et al.*, 2010; Nescerecka *et al.*, 2014). It is virtually impossible to completely remove microbes in water while delivering a safe product to consumers, and the use of disinfectants results in selection

Received 21 July, 2017; accepted 21 July, 2017.

*For correspondence. E-mail bfsm@env.dtu.dk; Tel. +45 45251600; Fax +45 45932850.

Microbial Biotechnology (2017) 10(5), 1094–1097
doi:10.1111/1751-7915.12837

Funding Information

Villum Fonden.

of (potentially pathogenic) bacteria that are resistant to disinfectants in distribution systems (Chiao *et al.*, 2014). Disinfection can result in the creation of unfilled ecological niches, increasing opportunities for invasion of water supplies by foreign bacteria. The concomitant production of assimilable organic carbon (AOC) from the reaction of residual disinfectant with recalcitrant organic matter also results in new niches and increased microbial carrying capacity (Reckhow *et al.*, 1990; Fass *et al.*, 2003). With long residence times in distribution systems, disinfectant residual is often lost and is associated with microbial regrowth, implying that disinfection merely delays microbial growth rather than prevents it (Servais *et al.*, 1995). In all cases, this results in decreased biological stability of water. Combined with potential long-term health effects associated with disinfectants and disinfection by-products (Sadiq and Rodriguez, 2004), this leads us to propose that the use of disinfectants should be limited. Removal of pathogens preferably takes place early and is followed by biological treatment for the removal of disinfection by-products and other chemical contaminants. In this way, a biologically stable product with low nutrient concentrations is obtained in which the absolute abundance and composition of the microbial community does not vary substantially throughout the distribution network (Prest *et al.*, 2016). This drinking water microbiome can be established using biological filtration steps that result in a natural resident community in the distributed water (Pinto *et al.*, 2012; Lautenschlager *et al.*, 2014). Ideally, this microbial community will be diverse and therefore will be more resistant to invasion than disinfected communities where unfilled niches would exist (Kinnunen *et al.*, 2016). Nonetheless, further research on factors that improve resistance to invasion, and examination of the capacity of common pathogens to invade drinking water microbiomes, needs to be conducted.

The most common use of microbial biotechnology in drinking water treatment is biological filtration. This involves the filtration of oxic or oxygenated water through granular media such as sand, granular activated carbon (GAC) or anthracite and may include slow sand filtration, rapid sand filtration (gravity or pressurized) or bank filtration. Microorganisms grow on the surface of the medium and are involved in removing a range of substances depending on the source water (Gülay *et al.*, 2014). Biological filtration is used for the removal of inorganic compounds (e.g. ammonium, nitrite, sulphide, methane, iron and manganese; de Vet *et al.*, 2011; Tatari *et al.*, 2012, 2016; Lee *et al.*, 2014), organic compounds (with or without prior ozonation) including natural organic matter (DeVries *et al.*, 2012) as well as a wider array of organic pollutants such as pesticides (Hedegaard and Albrechtsen, 2014; Hedegaard *et al.*, 2014), pharmaceuticals (Petrovic *et al.*, 2009),

disinfection by-product precursors (McKie *et al.*, 2015) and arsenic (Katsoyiannis and Zouboulis, 2004). Adaptation of biological filtration systems with zero valent iron can also be used for the removal of radionuclides such as uranium (Gottinger *et al.*, 2013), and other adsorbents could be incorporated into biological filters for the removal of heavy metals such as lead and cadmium (Ali and Gupta, 2007). In some regions, biological filtration is used as the sole means of water treatment in single or successive rapid sand filters for the treatment of aerated groundwater (e.g. Denmark) or as a sequential ozonation, and filtration treatment train for surface water treatment (e.g. Zurich). In regions where oxidative treatment is used, biological filtration is commonly used after oxidation to remove the produced AOC. Bioaugmentation of biological filters is increasingly being investigated for the removal of recalcitrant contaminants (Ho *et al.*, 2007; Benner *et al.*, 2013; Horemans *et al.*, 2017). Bioaugmentation has the potential to increase the diversity of pollutants and micropollutants that are degradable in biological filters. This is an important development, as increasing water re-use necessitates improved technologies for pollutant removal. For bioaugmentation to be a successful strategy in the long-term, further research is needed to understand the ability of bioaugmented organisms to invade and establish in a resident microbial community, and then grow under the oligotrophic conditions typical of drinking water filters. The current effort at elucidating the complete composition and metabolic potential of biofiltration communities (e.g. Gülay *et al.*, 2016; Palomo *et al.*, 2016), the availability of different granular media types, and the lower footprint of pressurized filtration units, is leading the way towards truly engineered biofiltration processes for potable water preparation.

Membrane-based biofilm reactors have also been investigated for the removal of a wide range of recalcitrant drinking water contaminants. Reductive treatment of oxidized compounds such as bromate, nitrate, selenate/selenite, chromate, perchlorate/chlorate/chlorite and arsenite – which can be primary pollutants in various groundwater sources – can be achieved using membrane biofilm reactors (MbfR) fed with hydrogen or methane as electron donor (Nerenberg and Rittmann, 2004; Rittman, 2006). In these cases, the pollutant to be removed is respired by the microbial community, which grows on the membrane surface, and electron donor is supplied via the membrane lumen. MbfRs have also been tested for the treatment of diverse organic contaminants including BTEX and chlorinated solvents (Syron and Casey, 2008) and pharmaceuticals (Kim *et al.*, 2010). While the MbfR allows for very small footprint reactors, where exact dosing control of electron donors can lead to cost-efficient biotreatment technologies with engineered biofilms (Nerenberg, 2016), it remains to be

examined whether the increased operational complexity (supply of gasses) and investment costs (membranes) provides a sufficient advantage over traditional biofiltration solutions that would depend on soluble electron donor additions (e.g. Upadhyaya *et al.*, 2010).

In summary, biological methods for the removal of common as well as context-specific and recalcitrant contaminants are available. We believe that increased exploitation of biological processes for drinking water treatment is the best way to achieve the provision of safe water globally. Biological processes are generally less costly and less energy intensive than advanced chemical and physical removal processes and can be effective for the removal of the majority of relevant contaminants. Furthermore, biological filtration processes at the end of treatment trains ensure the presence of a biodiverse drinking water microbiome that may be more effective than disinfection at reducing pathogen invasion.

Conflict of interest

None declared.

References

- Ali, I., and Gupta, V.K. (2007) Advances in water treatment by adsorption technology. *Nat Protoc* **1**: 2661–2667.
- Benner, J., Helbling, D.E., Kohler, H.-P.E., Wittebol, J., Kaiser, E., Prasse, C., *et al.* (2013) Is biological treatment a viable alternative for micropollutant removal in drinking water treatment processes? *Water Res* **47**: 5955–5976.
- Chiao, T.-H., Clancy, T.M., Pinto, A., Xi, C., and Raskin, L. (2014) Differential resistance of drinking water bacterial populations to monochloramine disinfection. *Environ Sci Technol* **48**: 4038–4047.
- DeVries, S.L., Liu, W., Wan, N., Zhang, P., and Li, X. (2012) Biodegradation of MIB, geosmin and microcystin-LR in sand columns containing Taihu lake sediment. *Water Sci Technol* **12**: 691–698.
- Fass, S., Block, J., Boualam, M., Gauthier, V., Gatel, D., Cavard, J., *et al.* (2003) Release of organic matter in a discontinuously chlorinated drinking water network. *Water Res* **37**: 493–500.
- Gottinger, A.M., McMartin, D.W., Wild, D.J., and Moldovan, B. (2013) Integration of zero valent iron sand beds into biological treatment systems for uranium removal from drinking water wells in rural Canada. *Can J Civ Eng* **40**: 945–950.
- Gülay, A., Tatari, K., Musovic, S., Mateiu, R.V., Albrechtsen, H.-J., and Smets, B.F. (2014) Internal porosity of mineral coating supports microbial activity in rapid sand filters for groundwater treatment. *Appl Environ Microbiol* **80**: 7010–7020.
- Gülay, A., Musovic, S., Albrechtsen, H.-J., Al-Soud, W.A., Sørensen, S.J., and Smets, B.F. (2016) Ecological patterns, diversity and core taxa of microbial communities in groundwater-fed rapid gravity filters. *ISME J* **10**: 2209–2222.
- Hammes, F., Berney, M., Wang, Y., Vital, M., Köster, O., and Egli, T. (2008) Flow-cytometric total bacterial cell counts as a descriptive microbiological parameter for drinking water treatment processes. *Water Res* **42**: 269–277.
- Hedegaard, M.J., and Albrechtsen, H.J. (2014) Microbial pesticide removal in rapid sand filters for drinking water treatment – potential and kinetics. *Water Res* **48**: 71–81.
- Hedegaard, M.J., Arvin, E., Corfitzen, C.B., and Albrechtsen, H.J. (2014) Mecoprop (MCP) removal in full-scale rapid sand filters at a groundwater-based waterworks. *Sci Total Environ* **499**: 257–264.
- Ho, L., Hoefel, D., Bock, F., Saint, C.P., and Newcombe, G. (2007) Biodegradation rates of 2-methylisoborneol (MIB) and geosmin through sand filters and in bioreactors. *Chemosphere* **66**: 2210–2218.
- Horemans, B., Raes, B., Vandermaesen, J., Simanjuntak, Y., Brocatius, H., T'Syen, J., *et al.* (2017) Biocarriers improve bioaugmentation efficiency of a rapid sand filter for the treatment of 2,6-dichlorobenzamide-contaminated drinking water. *Environ Sci Technol* **51**: 1616–1625.
- Katsogiannis, I.A., and Zouboulis, A.I. (2004) Application of biological processes for the removal of arsenic from groundwaters. *Water Res* **38**: 17–26.
- Kim, J., Song, I., Lee, S., Kim, P., Oh, H., Park, J., and Choung, Y. (2010) Decomposition of pharmaceuticals (sulfamethazine and sulfathiazole) using oxygen-based membrane biofilm reactor. *Desalination* **250**: 751–756.
- Kinnunen, M., Dechesne, A., Proctor, C., Hammes, F., Johnson, D., Quintela-Baluja, M., *et al.* (2016) A conceptual framework for invasion in microbial communities. *ISME J* **10**: 2773–2775.
- Lautenschlager, K., Boon, N., Wang, Y., Egli, T., and Hammes, F. (2010) Overnight stagnation of drinking water in household taps induces microbial growth and changes in community composition. *Water Res* **44**: 4868–4877.
- Lautenschlager, K., Hwang, C., Ling, F., Liu, W.-T., Boon, N., Köster, O., *et al.* (2014) Abundance and composition of indigenous bacterial communities in a multi-step biofiltration-based drinking water treatment plant. *Water Res* **62**: 40–52.
- Lee, C.O., Boe-hansen, R., Musovic, S., Smets, B., Albrechtsen, H., and Binning, P. (2014) ScienceDirect Effects of dynamic operating conditions on nitrification in biological rapid sand filters for drinking water treatment. *Water Res* **64**: 226–236.
- Logsdon, G.S., Kohne, R., Abel, S., and LaBonde, S. (2011) Slow sand filtration for small water systems. <https://doi.org/10.1139/s02-025>
- McKie, M.J., Taylor-Edmonds, L., Andrews, S.A., and Andrews, R.C. (2015) Engineered biofiltration for the removal of disinfection by-product precursors and genotoxicity. *Water Res* **81**: 196–207.
- Nerenberg, R. (2016) The membrane-biofilm reactor (MBfR) as a counter-diffusional biofilm process. *Curr Opin Biotechnol* **38**: 131–136.
- Nerenberg, R., and Rittmann, B.E. (2004) Hydrogen-based, hollow-fiber membrane biofilm reactor for reduction of

- perchlorate and other oxidized contaminants. *Water Sci Technol* **49**: 223–230.
- Nescerecka, A., Rubulis, J., Vital, M., Juhna, T., and Hammes, F. (2014) Biological instability in a chlorinated drinking water distribution network. *PLoS ONE* **9**: e96354.
- Palomo, A., Jane Fowler, S., Gülay, A., Rasmussen, S., Sichert-Ponten, T., and Smets, B.F. (2016) Metagenomic analysis of rapid gravity sand filter microbial communities suggests novel physiology of *Nitrospira* spp. *ISME J* **10**: 2569–2581.
- Petrovic, M., de Alda, M.J.L., Diaz-Cruz, S., Postigo, C., Radjenovic, J., Gros, M., and Barcelo, D. (2009) Fate and removal of pharmaceuticals and illicit drugs in conventional and membrane bioreactor wastewater treatment plants and by riverbank filtration. *Philos Trans A Math Phys Eng Sci* **367**: 3979–4003.
- Pinto, A.J., Xi, C., and Raskin, L. (2012) Bacterial community structure in the drinking water microbiome is governed by filtration processes. *Environ Sci Technol* **46**: 8851–8859.
- Prest, E.I., Hammes, F., van Loosdrecht, M.C.M., and Vrouwenvelder, J.S. (2016) Biological stability of drinking water: controlling factors, methods, and challenges. *Front Microbiol* **7**: 45.
- Reckhow, D.A., Singer, P.C., and Malcolm, R.L. (1990) Chlorination of humic materials: byproduct formation and chemical interpretations. *Environ Sci Technol* **24**: 1655–1664.
- Rittman, B.E. (2006) The membrane biofilm reactor: the natural partnership of membranes and biofilm. *Water Sci Technol* **53**: 219–225.
- Sadiq, R., and Rodriguez, M. (2004) Disinfection by-products (DBPs) in drinking water and predictive models for their occurrence: a review. *Sci Total Environ* **321**: 21–46.
- Schubert, J. (2002) Hydraulic aspects of riverbank filtration—field studies. *J Hydrol* **266**: 145–161.
- Servais, P., Laurent, P., and Randon, G. (1995) Comparison of the bacterial dynamics in various French distribution systems. *J Water Supply Res Technol AQUA* **44**: 10–17.
- Syron, E., and Casey, E. (2008) Membrane-aerated biofilms for high rate biotreatment: performance appraisal, engineering principles, scale-up, and development requirements. *Environ Sci Technol* **42**: 1833–1844.
- Tatari, K., Smets, B.F. and Albrechtsen, H.J. (2012) Effect of surface loading fluctuations in rapid sand-filters used to remove ammonium from drinking water.
- Tatari, K., Smets, B.F., and Albrechtsen, H.-J. (2016) Depth investigation of rapid sand filters for drinking water production reveals strong stratification in nitrification biokinetic behavior. *Water Res* **101**: 402–410.
- Upadhyaya, G., Jackson, J., Clancy, T.M., Hyun, S.P., Brown, J., Hayes, K.F., and Raskin, L. (2010) Simultaneous removal of nitrate and arsenic from drinking water sources utilizing a fixed-bed bioreactor system. *Water Res* **44**: 4958–4969.
- de Vet, W.W.J.M., Dinkla, I.J.T., Rietveld, L.C., and van Loosdrecht, M.C.M. (2011) Biological iron oxidation by *Gallionella* spp. in drinking water production under fully aerated conditions. *Water Res* **45**: 5389–5398.